

Boiler information letter

ATTACK WOOD & PELLET					
Condensing boiler	no	Combined boiler for solid fuel	no	Combined boiler	yes
Fuel	Prefered fuel (only one)		Other suitable fuel/fuels		
Wood logs, humidity content $\leq 25\%$	no		yes		
Wood logs, humidity content 15 - 35 %	no		no		
Wood chips, humidity content $> 35\%$	no		no		
Compressed wood in form of pellets or briquettes	yes		no		
Scobs, humidity content $\leq 50\%$	no		no		
Other wood biomass	no		no		
No wood biomass	no		no		
Black coal	no		no		
Brown coal (including of briquettes)	no		no		
Coke	no		no		
Anthracite	no		no		
Briquettes from mixture of fossil fuels	no		no		
Other fossil fuels	no		no		
Briquettes from mixture of biomass (30 -70%) and fossil fuels	no		no		
Other mixture of biomass and fossil fuels	no		no		
Facilities by activity on preferred fuel					
Seasonal energetic efficiency of indoor rooms heating η_s [%]:					77
Index of energy efficiency EEI:					115
Title	Symbol	Unit	Value		
Usefull heating capacity					
- by the nominal heating output	P_n	28,1	kW		
- by the nominal heating output [30%/50%]	P_p	8,9	kW		
Usefull efficiency					
- by the nominal heating output	η_n	83,5	%		
- by the nominal heating output [30%/50%]	η_p	82,8	%		
Combined boilers for solid fuels					
Electrical efficiency by the nominal heating output	$\eta_{el, n}$	-	%		
Consumption of additional electric energy					
- by the nominal heating output	$e_{l, max}$	0,094	kW		
- by the nominal heating output [30%/50%]	$e_{l, min}$	0,047	kW		
- integral secondary device for reduction of emissions			kW		
- in emergency mode	P_{SB}	0,049	kW		
Contact	ATTACK, s.r.o. Dielenská Kružná 5020 Vrútky 038 61				