



Product Service

Attestation of Conformity

No. N8A 112610 0002 Rev. 00

Holder of Certificate: **ATTACK, s.r.o.**
Dielenská Kružná 5020
038 61 Vrútky
SLOVAKIA

Product: **Heat pumps**
(DC Inverter Air to Water Heat Pump Unit)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111210191801

Date, 2021-07-02

(Sam Yang)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 112610 0002 Rev. 00

Model(s):

Outdoor unit A1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 6 kW/OA

Indoor unit A1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 6 kW/IA

Outdoor unit B1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 9 kW/OA

Indoor unit B1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 9 kW/IA

Outdoor unit C1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 12 kW/OA

Indoor unit C1:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 12 kW/IA

Brand: **ATTACK**



Parameters:

Rated Voltage: 220-240V
 Rated Frequency: 50Hz
 Protection Class: Class I
 Degree of Protection: IPX4 for outdoor unit,
 IPX0 for indoor unit.
 Refrigerant: R32

Code	Outdoor unit	Indoor unit	Rated input cooling mode (W)	Rated input heating mode (W)
A1	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 6 kW/OA	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 6 kW/IA	1691W	5500W (2500W+3000W)

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 112610 0002 Rev. 00

B1	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 9 kW/OA	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 9 kW/IA	2410W	6200W (3200W+3000W)
C1	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 12 kW/OA	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 12 kW/IA	2610W	6900W (3900W+3000W)

**Tested
according to:**

EN 60335-1:2012/A2:2019
EN 60335-2-40:2003/A13:2012
EN 62233:2008

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.